




EC TYPE - EXAMINATION In accordance with Module B of Directive 2014/90/EU on Marine Equipment Directive		Certificate N° 14/UK/3332-1-Rev 0 Page 1/3
Manufacturer	Name	SENTURA GROUP
	Address	Sentura House 3 Lands End Way, Oakham Rutland UK, LE15 6RB
<p><u>Concerned Equipment:</u></p> <p>Portable and mobile fire extinguishers</p> <p>Models : See page 2/3 and 3/3</p>		
<p>The manufacturer is allowed to affix the marine mark  (followed by the NOBO n° and the year of manufacturing) to the approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with</p> <p style="text-align: center;">The approval is valid until 02/03/2024</p>		
<p>APRAGAZ, acting within the scope of its notification for the above mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7&EN1866-1 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.</p>		
Date : 04/02/2019	Name : Ch. Leplat	Position General Manager
Notified body identification number :	0029	Signature
Third Party Authority stamp :	APRAGAZ Belgium Inspecting Authority	
Third Party Authority reference :	P15744/001	

EC TYPE - EXAMINATION

In accordance with Module B of Directive 2014/90/EU
on Marine Equipment Directive

Certificate N°

14/UK/3332-1-Rev 0

Page 2/3



Model	Assembly drawing	Capacity & Type of agent	Fire Class	Reference EN3-7 report	Tmin/ Tmax
FMP1	TB/EN/T-1P2	1 Kg ABC40%	8A 34B C	275446 -30/11/11 BRE	-30°C/ +60°C
FMPA1	TB/EN/T-1P3 (ALI)	1 Kg ABC40%	8A 34B C	275596 -23/08/12 BRE	-30°C/ +60°C
FXP1	TB/EN/T-1P1	1 Kg ABC40%	8A 34B C	275446 -30/11/11 BRE	-30°C/ +60°C
PPP1	TB/EN/T-1P1	1 Kg ABC85%	8A 55B C	275447 -30/11/11 BRE	-30°C/ +60°C
FXP2-FMP2	TB/EN/T-2P	2 Kg ABC40%	13A 89B C	275448 -01/11/11 BRE	-30°C/ +60°C
FXP3	TB/EN/T-3P	3 Kg ABC40%	21A 113B C	280703 -07/09/12 BRE	-30°C/ +60°C
FXP4	TB/EN/T-4P	4 Kg ABC40%	27A 144B C	274193 -30/11/11 BRE	-30°C/ +60°C
FXP6	TB/EN/T-6P1	6 Kg ABC40%	43A 233B C	275449 -01/11/11 BRE	-30°C/ +60°C
PPP6	TB/EN/T-6P1	6 Kg ABC90%	55A 233B C	275450 -01/11/11 BRE	-30°C/ +60°C
FXP9	TB/EN/T-9P1	9 Kg ABC40%	55A 233B C	275452 -30/11/11 BRE	-30°C/ +60°C
FXP12	TB/EN/T-12P	12 Kg ABC40%	55A 233B C	285/7361051 -2010 BSI	-30°C/ +60°C
FXF2-FMF2	TB/EN/T-2L	2 Lt Genex 1R	8A 55B	275601 -03/01/12 BRE	+5°C/ +60°C
FXWC2	TB/EN/T-2L1	2 Lt Fatseal	8A 34B 25F	280706 -07/09/12 BRE	+5°C/ +60°C
FMABF2	TB/EN/T-2L1	2 Lt Fatseal	8A 34B 25F	280706 -07/09/12 BRE	+5°C/ +60°C
FXF3	TB/EN/P-3L	3 Lt Genex 1R	13A 89B	280705 -07/09/12 BRE	+5°C/ +60°C
FXWC3	TB/EN/P-3L2	3 Lt Fatseal	13A 70B 40F	287032 -31/05/13 BRE	+5°C/ +60°C
FXF6	TB/EN/T-6L	6 Lt Genex ESC	21A 144B	275602 -03/01/12 BRE	+5°C/ +60°C
PPF6	TB/EN/T-6L	6 Lt Genex 1R	27A 183B	287034 -24/05/13 BRE	+5°C/ +60°C
FXWC6	TB/EN/T-6P-1	6 Lt Fatseal	21A 113B 75F	275607 -24/01/12 BRE	+5°C/ +60°C
FXW6	TB/EN/T-6L1	6 Lt Water Spray	13A	275606 -24/01/12 BRE	+5°C/ +60°C
FXF9	TB/EN/T-9L	9 Lt Genex ESC	27A 233B	275603 -30/05/12 BRE	+5°C/ +60°C
FXW9	TB/EN/P-9L	9 Lt Water Jet	21A	285/7361051 -2010 BSI	+5°C/ +60°C
ESW3	TB/EN/T-3L	3 Lt Pentspray	13A	275604 -03/01/12 BRE	+5°C/ +60°C
ESW6	TB/EN/T-6L1	6 Lt Pentspray	27A	275605 -03/01/12 BRE	+5°C/ +60°C

Date : 04/02/2019

Name : Ch. Leplat

Position

General Manager

Notified body identification
number :

0029

Signature

Third Party Authority stamp :

A P R A G A Z
Belgium
Inspecting
Authority

Third Party Authority reference :

P 15744/001

EC TYPE - EXAMINATION**In accordance with Module B of Directive 2014/90/EU
on Marine Equipment Directive****Certificate N°
14/UK/3332-1-Rev 0****Page 3/3**

<u>Model</u>	<u>Assembly drawing</u>	<u>Capacity & Type of agent</u>	<u>Fire Class</u>	<u>Reference EN3-7 report</u>	<u>Tmin/Tmax</u>
FXC2S	TB-CO-2-A	2 Kg CO2	34B	280707 - 17/10/12 BRE	-30°C/ +60°C
FXC5S	TB-CO-5-A	5 Kg CO2	70B	280708 - 19/11/12 BRE	-30°C/ +60°C
FXP25	TB/EN/E-25P	25 Kg ABC	IIB	275597 -10/12/12 BRE	-30°C/ +60°C
FXP50	TB/EN/E-50P	50 Kg ABC	IVB	282992 -10/12/12 BRE	-30°C/ +60°C
FXF50	TB/EN/E-50L	50 Lt AFFF	IVB	282994 -10/12/12 BRE	+5°C/ +60°C
FXP100	TB/EN/E-100P	100 Kg ABC	IVB	282993 -10/12/12 BRE	-30°C/ +60°C
FXF100	TB/EN/E-100L	100 Lt AFFF	IVB	282995 -10/12/12 BRE	+5°C/ +60°C

Date : 04/02/2019

Name : Ch. Leplat

Position **General Manager**Notified body identification
number :**0029**

Signature

Third Party Authority stamp :

APRAGAZ
Belgium
**Inspecting
Authority**

Third Party Authority reference :

P15744/001